

Certificate of Product Approval

Certificate Number: 1417a

Issue: 01

FirePro Systems Limited

6 Koumandarias & Spyrou Araouzou Street
Tonia Court No 2
6th Floor
Limassol
CY-3036
Cyprus

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Condensed Aerosol Generators
(refer to attached appendix for details)

Standards

SD0228 and Selected Clauses of prEN15276-1 and prEN15276-2 (Sept 2017)

Requirements and test methods for condensed aerosol extinguishing system components

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Sarah Colwell
Verifier

9 January 2018
Date of Issue

9 January 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1417a FirePro Systems Limited

Issue: 01

Condensed Aerosol Generator

Product Name	Description	LPCB Ref. No
FP-1200 (note 1)	Condensed aerosol generator (electrical activation only) and mounting bracket	1417a/01
FP-2000 (note 1)	Condensed aerosol generator (electrical activation only) and mounting bracket	1417a/02
FP-3000 (note 1)	Condensed aerosol generator (electrical activation only) and mounting bracket	1417a/03
FP-4200 (note 2)	Condensed aerosol generator (electrical activation only) and mounting bracket	1417a/04
FP-5700 (note 1)	Condensed aerosol generator (electrical activation only) and mounting bracket	1417a/05

General Notes:

This approval covers the components listed when used in accordance with the FirePro "Instruction, information and user manual" version 7.0, dated 18th October 2017.

This approval does not cover system design, system performance or installation.

The Application Densities for these components, as defined in prEN15276-1 Clause 5.2, for the following applications are:

- Class A (surface burning fire only) – 97.6 g/m³
- Class B – 68.6 g/m³

The component approval does not cover applications for:

- Potentially Explosive Atmospheres, or
- Grouped Power or Data Cables.

Table Notes:

- (1) The Product is available in 4 variants:
 - FP-xxxx – Mild Steel Body
 - FP-xxxxS – Stainless Steel Body
 - FP-xxxxT – Mild Steel Body; Thermal Activation Model Variant in Electrical Activation Mode Only
 - FP-xxxxTS– T Variant with Stainless Steel Body
- (2) The Product is available in 2 variants:
 - FP-xxxxT – Mild Steel Body, Thermal Activation Model Variant in Electrical Activation Mode Only
 - FP-xxxxTS– T Variant with Stainless Steel Body

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A.C. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

9 January 2018

Date of Issue

9 January 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre